NOTES: ALLOW MINIMUM OF 7 INCHES BEHIND ENCLOSURE FOR FULLY OPENED LID

( မ

- 1) FLIP LID IN OPEN POSITION
  2) GFI OUTLET AND SWITCH
  3) CALSENSE STAINLESS STEEL FACTORY
  ASSEMBLED ENCLOSURE
- (4) #6 BARE COPPER GROUND WIRE (5) (38" x 24" x 8") CONCRETE BASE
- (7) (5/8" x 8") COPPER GROUND ROD. INSTALL GROUND ROD 8' FROM ASSEMBLEY (SEE GROUNDING INSTRUCTIONS FOR MORE DETAILS) (6) FINISH GRADE 2" BELOW CONCRETE BASE (LAWN OR OTHER)
- 8 SCH 40 PVC ELECTRICAL SWEEP FOR GROUND WIRE (9)
- SCH 40 PVC ELECTRICAL SWEEP FOR FIELD WIRES (2 TYP)
- (1) MOUNTING J-BOLT (4 TYP)

